

S: TW

TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

APPARATUS A three-phase dry-type power transformer

DESIGNATION Cast Resin dry type transformer **SERIAL No.** 10020011

Rated power 3200 kVA
 Rated voltage 20 kV - 4 x 2,5% / 0,400 kV
 Connection symbol Dyn11
 Rated frequency 50 Hz

MANUFACTURER Unelectra International Corp.,
 Taoyuan, Taiwan

TESTED FOR Unelectra International Corp.,
 Taoyuan, Taiwan

TESTED BY KEMA HIGH-POWER LABORATORY and HIGH-VOLTAGE LABORATORY
 Utrechtseweg 310 - 6812 AR Arnhem - The Netherlands

DATE(S) OF TESTS 19, 28 and 29 September, 3 and 20 October 2011

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with the complete type test requirements of

IEC 60076 - 11 (2004)

This Type Test Certificate has been issued by KEMA following exclusively the STL Guides.

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page 4 and the dynamic ability to withstand short-circuits.

This Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate consists of 53 sheets in total.

This Certificate falls under the scope of the accreditation certificates L 020 and L 218 of the Dutch Council for Accreditation. See information sheet (page 2).

© Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only". The sealed and bound version of the Certificate is the only valid version.

KEMA Nederland B.V.



S.A.M. Verhoeven
 Director Testing, Inspections &
 Certification The Netherlands

Arnhem, 5 January 2012

PL ■ GC ■ MT ■

O: 70012645

Version: 1



1 Certificate

A Certificate contains a record of a series of type tests carried out strictly in accordance with a recognized standard. The equipment tested has fulfilled the requirements of this standard and the relevant ratings assigned by the manufacturer are endorsed by KEMA. The Certificate is applicable only to the equipment tested. KEMA is responsible for the validity and the contents of the Certificate.

The responsibility for conformity of any apparatus having the same designation as the one tested rests with the manufacturer. The Certificate contains the essential drawings and a description of the equipment tested.

Detailed rules are given in KEMA's Certification procedure.

2 Report of Performance

A Report of Performance contains a record of one or more tests which have been carried out according to the client's instructions. These tests are not necessarily in accordance with a recognized standard. The test results do not verify ratings of the test object.

KEMA issues three types of Reports of Performance:

2.1 *The tests have been carried out strictly in accordance with The apparatus has complied with the relevant requirements.*

This sentence will appear on the front page of a Report of Performance if the tests have been performed in accordance with a recognized standard, but the series of tests does not completely fulfil the requirements for a Certificate of Compliance (for example, if the number of test duties is not a complete series of type tests). The Report contains verified drawings and a description of the equipment tested. Detailed rules are given in KEMA's Certification procedure. The condition of the test object after the tests is assessed and recorded in the Report.

2.2 *The tests have been carried out in accordance with the client's instructions. Test procedure and test parameters were based on*

This sentence will appear on the front page of a Report of Performance if the number of tests, the test procedure and the test parameters are based on a recognized standard and related to the ratings assigned by the manufacturer. If the apparatus does not pass the tests such behaviour will be mentioned on the front sheet. Verification of the drawings (if submitted) and assessment of the condition after the tests is only done on the client's request.

2.3 *The tests have been carried out according to the client's instructions.*

This sentence will appear on the front page of a Report of Performance if the tests, test procedure and/or test parameters are not in accordance with a recognized standard.

3 Standards

When reference is made to a standard, and the date of issue is not stated, this applies to the latest issue, including amendments which have been officially published prior to the date of the tests.

4 Official and uncontrolled test documents

The official test documents of KEMA High-Power Laboratory are issued in bound form. Uncontrolled copies may be provided as loose sheets or as a digital file for convenience of reproduction by the client. The copyright has to be respected at all times.

5 Accuracy of measurement

In the table of test results the measured quantities are given in three digits. This method of presentation does not indicate an accuracy. The guaranteed uncertainty in the figures mentioned, taking into account the total measuring system, is less than 5%, unless mentioned otherwise.

6 Qualified by RvA (Dutch Council for Accreditation)

KEMA High-Power Laboratory and High-Voltage Laboratory have been entered in the RvA-register for laboratories under resp. Nrs. L 020 and L 218 for the testing services as defined in the Field of Accreditation.

The accreditation is carried out in accordance with ISO/IEC 17025.

TABLE OF CONTENTS:

INFORMATION SHEET2

IDENTIFICATION OF THE APPARATUS TESTED4
 Ratings assigned by the manufacturer4
 Description of apparatus tested4
 List of drawings4

GENERAL INFORMATION5
 The tests were witnessed by5
 The tests were observed by5
 The transformer was inspected by5

LEGEND6

REACTANCE MEASUREMENT OVERVIEW7

SUMMARY OF TESTS8

DUTY: Routine tests before short-circuit tests10
 Test date 11091910

DUTY: Partial discharge measurement before short-circuit test15
 Test date 11092115

DUTY: Short-circuit tests16
 Test circuit17
 Calculation sheet short-circuit current18
 Photograph before test19
 Tests 110928-4008 to 4010, 4012 to 4014, 4016 to 401820

CONDITION AFTER TEST29
 Photograph after test30

DUTY: Routine tests after short-circuit tests31
 Test date 11092931

DUTY: Determination of sound levels36
 Test date 11092936

DUTY: Partial discharge measurement after short-circuit test38
 Test date38

DUTY: Lightning impulse test (LI)39
 Test date 11100339

DUTY: Temperature-rise test46
 Test date 11102046

INSPECTION50

DRAWINGS51

RATINGS/CHARACTERISTICS ASSIGNED BY THE MANUFACTURER AND PROVED BY TESTS

Insulation level LI	125 kV
Voltage	20 kV - 4 x 2,5% / 0,400 kV
Power	3200 kVA
Current	92,4 / 4619 A
Short-circuit impedance	7,5 %
Connection symbol	Dyn11
Cooling method	AN
Frequency	50 Hz
Category	II
Apparent system power	500 MVA

DESCRIPTION OF APPARATUS TESTED

A three-phase dry-type power transformer

LIST OF DRAWINGS

The manufacturer has guaranteed that the equipment submitted for tests has been manufactured in accordance with the drawings mentioned below.

KEMA has verified that these drawings adequately represent the equipment tested.

The following drawings have been included in this Certificate:

Drawing No.	Rev. No.
BO-005535	0
B454-1052	0
B454-1053	0

The following drawings are only listed for reference and are kept in KEMA's files:

Drawing No.	Rev. No.
BO-005536	0
B430-0096	0
B430-0097	0
B451-5891	0
B451-5892	0

THE TESTS WERE WITNESSED BY**Name**Chen, A.
Chou, A.**Company**Unelectra International Corp.,
Taipei, Taiwan**THE TESTS WERE OBSERVED BY****Name**Ebbers, L.F.H.
Wiggers, R.**Company**KEMA High-Power Laboratory,
Arnhem, The Netherlands

Smeenk, S.

KEMA High-Voltage Laboratory,
Arnhem, The Netherlands**THE TRANSFORMER WAS INSPECTED BY****Name**

Wiggers, R.

CompanyKEMA,
Arnhem, The Netherlands